

NPort IA5000A

Quick Installation Guide

Version 5.1, September 2019

Technical Support Contact Information **www.moxa.com/support**

Moxa Americas:

Toll-free: 1-888-669-2872

Tel: 1-714-528-6777

Fax: 1-714-528-6778

Moxa China (Shanghai office):

Toll-free: 800-820-5036

Tel: +86-21-5258-9955

Fax: +86-21-5258-5505

Moxa Europe:

Tel: +49-89-3 70 03 99-0

Fax: +49-89-3 70 03 99-99

Moxa Asia-Pacific:

Tel: +886-2-8919-1230

Fax: +886-2-8919-1231

Moxa India:

Tel: +91-80-4172-9088

Fax: +91-80-4132-1045

MOXA®

© 2019 Moxa Inc. All rights reserved.

P/N: 1802051500316



Overview

The NPort IA5000A series of device servers deliver easy and reliable serial-to-Ethernet connectivity for the industrial automation market. The servers support several operation modes—TCP Server, TCP Client, UDP, Real COM, RFC2217, RTelnet, Pair Connection, and Ethernet Modem—ensuring the compatibility of network software, and are an ideal choice for connecting RS-232/422/485 serial devices, such as PLCs, sensors, meters, motors, drives, barcode readers, and operator displays.

Package Checklist

Before installing the NPort IA5000A Series device servers, verify that the package contains the following items:

- 1 NPort IA5150A/IA5250A/IA5450A Series device server
- Quick installation guide (printed)
- Warranty card

Optional Accessories

- **DR-4524:** 45W/2A DIN-Rail 24 VDC Power Supply with universal 85 to 264 VAC input
- **DR-75-24:** 75W/3.2A DIN-Rail 24 VDC Power Supply with universal 85 to 264 VAC input
- **DR-120-24:** 120W/5A DIN-Rail 24 VDC Power Supply with 88 to 132 VAC/176 to 264 VAC input by switch
- **WK-36-01:** Wall mounting kit

Note: Please notify your sales representative if any of the above items are missing or damaged.


Hardware Introduction

The NPort IA5150A Series has one RS-232 DB9 serial port and one RS-422/485 terminal block for serial data communication. The NPort IA5250A/IA5450A Series has two/four RS-232/422/485 3-in-1 DB9 serial ports for serial data communication. Each model has one 8-contact screw-type terminal block, which is located on the top for power input and relay output.


Dimensions

NPort IA5150A
NPort IA5150AI

NPort IA5250A
NPort IA5250AI



NPort IA5450A
NPort IA5450AI



The Reset to Default Button—Depress the Reset to default button for 5 continuous seconds to load the factory default settings. Use a pointed object, such as a straightened paper clip or toothpick, to depress the Reset to default button. This will cause the Ready LED to blink on and off. The factory default settings are loaded once the Ready LED stops blinking (after about 5 seconds). At this point, you can release the Reset to default button.

NPort IA5000A Series LED Indicators (front panel)

| Name | Color | Function |
|----------------|--------------|--|
| PWR1, PWR2 | Red | Power is being supplied to power input PWR1, PWR2. |
| Ready | Red | Steady on: Power is on and the NPort IA5000A Series is booting up. Blinking: Indicates an IP conflict, the DHCP or BOOTP server did not respond properly, or a relay output occurred. |
| | Green | Steady on: Power is on and the NPort IA5000A Series is functioning normally. Blinking: The device server has been located by the Administrator's "Locate" function. |
| | Off | Power is off, or a power error condition exists. |
| E1, E2 | Orange | 10 Mbps Ethernet connecting. |
| | Green | 100 Mbps Ethernet connecting. |
| | Off | Ethernet cable is disconnected, or has a short. |
| P1, P2, P3, P4 | Orange | Serial port is receiving data. |
| | Green | Serial port is transmitting data. |
| | Off | No data is being transmitted or received through the serial port. |

Hardware Installation Procedure


STEP 1: After removing the NPort IA5000A Series from the box, the first thing you should do is connect the power adaptor. Connect the 12-48 VDC power line with the NPort IA5000A Series' terminal block, or connect the DIN-Rail power supply with the NPort IA5000A Series' terminal block.

STEP 2: Connect the NPort IA5000A Series to a network. Use a standard straight-through Ethernet cable to connect to a Hub or Switch. When setting up or testing the NPort IA5000A Series, you might find it convenient to connect directly to your computer's Ethernet port. In this case, use a cross-over Ethernet cable.

STEP 3: Connect the NPort IA5000A Series' serial port to a serial device.

STEP 4: The NPort IA5000A Series is designed to be attached to a DIN-Rail or mounted on a wall. For DIN-Rail mounting, push down the spring and properly attach it to the DIN-Rail until it "snaps" into place. For wall mounting, install the wall mount kit (optional) first, and then screw the device onto the wall.

The following figure illustrates the two mounting options:



Software Installation Information

For the NPort's configuration, the default IP address of the NPort is: 192.168.127.254. You may log in with the account name **admin** and password **moxa** to change any setting to meet your network topology (e.g., IP address) or serial device (e.g., serial parameters).


For software installation, download the relative utilities from Moxa's website

https://www.moxa.com/support/support_home.aspx?isSearchShow=1

- Download the NPort Windows Driver Manager and install it as the driver to run with Real COM mode of the NPort Series.
- Execute NPort Windows Driver Manager; then map the virtual COM ports on your Windows platform.
- You may refer to the DB9 Male pin assignment section to loop back pin 2 and pin 3 for the RS-232 interface to carry out a self test on the device.
- Use HyperTerminal or a similar program (you may download Moxa's program, called PComm Lite) to test whether the device is good or not.

Pin Assignments and Cable Wiring

RS-232/422/485 (Male DB9) Pinouts



| PIN | RS-232 | RS-422/ RS-485 (4W) | RS-485 (2W) |
|-----|--------|------------------------|----------------|
| 1 | DCD | TxD-(A) | - |
| 2 | RXD | TxD+(B) | - |
| 3 | TXD | RxD+(B) | Data+(B) |
| 4 | DTR | RxD-(A) | Data-(A) |
| 5 | GND | GND | GND |
| 6 | DSR | - | - |
| 7 | RTS | - | - |
| 8 | CTS | - | - |
| 9 | - | - | - |


RS-422/2W RS-485/4W RS-485 (Terminal Block) Pinouts




| PIN | RS-485 (2W) | RS-422/RS-485 (4W) |
|-----|-------------|--------------------|
| 1 | - | TxD+(B) |
| 2 | - | TxD-(A) |
| 3 | Data+(B) | RxD+(B) |
| 4 | Data-(A) | RxD-(A) |
| 5 | GND | GND |

Four cables are available as optional accessories that can be used to connect the NPort IA5000A Series to RS-232 serial devices. For your convenience, we show precise cable wiring diagrams for each of the two cables.

Female DB9 to Male DB9



Female DB9 to Male DB25



ATEX and IECEx Information




1. DEMKO Certification number: 12 ATEX 1014487X
IEC Certification Number: IECEx UL 13.0024X (only for models with suffix -CT or -IEX)
2. Ambient Temperature Range ($-40^{\circ}\text{C} \leq T_{\text{amb}} \leq 75^{\circ}\text{C}$)
3. Certification String: Ex nA nC IIC T3 Gc

4. Standards Covered:
EN 60079-0:2012+A11:2013, IEC 60079-0 Ed 6.0,
EN 60079-15:2010, IEC 60079-15 Ed 4.0
5. The conditions of safe usage:
 - The Ethernet Communications Devices are intended for mounting in a tool-accessible ATEX-Certified or IECEx-Certified (for models with the suffix -CT or -IEX) IP54 enclosure and used in an area of not more than pollution degree 2 as defined by IEC/EN 60664-1 or IEC 60664-1 (for models with the suffix -CT or -IEX).
 - Conductors suitable for use in an ambient temperature greater than 91°C must be used for the power supply terminal.
 - A 4 mm² conductor must be used when connection to the external grounding screw is utilized.
 - Provisions shall be made, either in the equipment or external to the equipment, to prevent the peak rated voltage being exceeded by the transient disturbances of more than 140%.
6. Terminal block information.
 - Input Terminal Block (J1)—Dinkle Enterprise Co, Ltd, Cat. No. 5EHDR-08P, rated 300V, 10A, 105°C, suitable for 28-12 AWG (0.12-3.31 mm²) wire size, torque value 4.5 lb-in (0.508 N-m). Terminal blocks do not accommodate more than one individual conductor per clamping point. Mechanically secured by two screws.
 - Signal Channel Terminal Block (J2, for the NPort IA5150A Series only)—Dinkle Enterprise Co, Ltd, Cat. No. 5EHDR-05P, rated 300V, 10A, 105°C, mating with Cat. No. 5ESDV-05P, rated 300V, 10A, 105°C, suitable for 28-12 AWG (0.12-3.31mm²) wire size, torque value 4.5 lb-in (0.508 N-m). Terminal blocks do not accommodate more than one individual conductor per clamping point. Mechanically secured by two screws.
7. Address: Moxa Inc, 4th Fl, No.135, Lane 235, Baoqiao Road, Xindian District, New Taipei City, 231 Taiwan


Pull-high, Pull-low, and Terminator for RS-485


Remove the NPort IA5000A's top cover and you will find DIP switches to adjust each serial port's pull-high, pull-low, and terminator.

NPort IA5150A Series



NPort IA5250A Series





| | 1 | 2 | 3 |
|-----|--------------------|-------------------|--------------|
| SW | Pull-high resistor | Pull-low resistor | Terminator |
| ON | 1 k Ω | 1 k Ω | 120 Ω |
| OFF | 150 k Ω * | 150 k Ω * | -* |

*Default

| Model | Power Input |
|----------------------|------------------------------------|
| NPort IA5150A Series | 12 to 48 VDC, max. 512 mA, Class 2 |
| NPort IA5250A Series | |
| NPort IA5450A Series | |

| | |
|-------------------------------------|-------------------------|
| Relay Output | 24 VDC, 1 A, resistance |
| Maximum Surrounding Air Temperature | 75°C |